

BACnet CONFORMANCE CERTIFICATE



No. BTL-30537

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.15. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 15.2 and the BTL Testing Policies, see Test Report number TC50950 of Protocol Test Lab.

Product name (B-ASC)
Compact actuating room automation station
Model(s) DXR1.E02PLZ-112, DXR1.E09PDZ-112, DXR1.E09PDZ-113, DXR1.E10PL-112, DXR1.E10PL-113
Firmware version
FW=03.54.02.03;SVS-300.6:SBC=15.00;ISC=01.00;
Vendor
Siemens
Theilerstrasse 1a
6300 Zug, Switzerland

This certificate is valid until **31-Mar-2025**.

24-Jan-2020

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann
Head of Certification Body