

BACnet CONFORMANCE CERTIFICATE



No. BTL-30683-1

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.15. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 16.1 and the BTL Testing Policies, see Test Report number TC51202 of Protocol Test Lab.

Product name (B-BC,B-BBMD,B-RTR)
DESIGO PXC4 and PXC5 Automation Station
Model(s) PXC5.E003, PXC4.M16, PXC4.E16
Software version
FW=02.11.02.155 (PXC5.E003)
FW=02.11.02.255 (PXC4.M16, PXC4.E16)
Vendor
Siemens Schweiz AG
Theilerstrasse 1a
6300 Zug, Switzerland

This certificate is valid until **31-Mar-2026**.

04-Feb-2021

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann
Head of Certification Body