

# BACnet CONFORMANCE CERTIFICATE



**No. BTL-30740**

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.15. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 16.1 and the BTL Testing Policies, see Test Report number TC51229 of Protocol Test Lab.

Product name (B-AAC)
<b>Desigo PXC3 and DXR2 Automation Stations</b>
<b>Model(s)* DXR2.y-yyy, DXP2.E18-110BR, DXP2.M18-110BR, PXC3.Ez-z</b>
Firmware version
<b>1.21</b>
Vendor
<b>Siemens Schweiz AG</b>
<b>Theilerstrasse 1a</b>
<b>6300 Zug, Switzerland</b>

\* where y,z is according to listing information

This certificate is valid until **31-Mar-2026**.

**08-Jul-2021**

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann  
Head of Certification Body