


BACnet CONFORMANCE CERTIFICATE



No. BTL-30981

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.15. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 18.1 and the BTL Testing Policies, see Test Report number TC51275 of Protocol Test Lab.

Product name (B-BC,B-BBMD,B-RTR,B-SCHUB)
Desigo PXC7, PXC5 and PXC4 Automation Station
Model(s) PXC7.E400L, PXC7.E400S, PXC7.E400M, PXC5.E003, PXC4.M16, PXC4.M16S, PXC4.E16, PXC4.E16S
Firmware version
FW: V02.20.152
Vendor
Siemens
Theilerstrasse 1a
6300 Zug, Switzerland

This certificate is valid until **31-Mar-2027**.

26-Jan-2023

Date of Initial Certification

Dipl.-Ing. G. Weinmann
Head of Certification Body