

# BACnet CONFORMANCE CERTIFICATE



## No. BTL-31066

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.15. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 20.0 and the BTL Testing Policies, see Test Report number TC51325 of Protocol Test Lab.

Product name (B-BC,B-BBMD,B-RTR,B-SCHUB)
<b>APOGEE PXC7.A and PXC4.A Automation Station</b>
<b>Model(s) PXC7.E400.A, PXC4.E16.A</b>
Firmware version
<b>02.20.155.13, 02.20.184.10</b>
Vendor
<b>Siemens</b>
<b>Theilerstrasse 1a</b>
<b>6300 Zug, Switzerland</b>

This certificate is valid until **31-Mar-2028**.

**13-Sep-2023**

Date of Initial Certification

A handwritten signature in blue ink, appearing to read 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann  
Head of Certification Body