

BACnet CONFORMANCE CERTIFICATE



No. BTL-31384

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.15. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 18.0 and the BTL Testing Policies, see Test Report number TC51233 of Protocol Test Lab.

Product name (B-ASC)
Intelligent Valve
Model(s)* ASE4U10A (EVG4Ux,EVF4Ux,EXG4Ux,EXF4Ux), ASE4U10D (EVF4Ux)
Firmware version
1.23.11783
Vendor
Siemens
Theilerstrasse 1a
6300 Zug, Switzerland

* where x is according to listing information

This certificate is valid until **31-Mar-2026**.

19-Aug-2025

Date of Initial Certification

Dipl.-Ing. G. Weinmann
Head of Certification Body