


# BACnet CONFORMANCE CERTIFICATE



## No. BTL-31506

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.18. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 26.0 and the BTL Testing Policies, see Test Report number TC51503 of Protocol Test Lab.

Product name (B-AAC)
<b>Designo PXC3 and DXR2 Automation Stations</b>
<b>Model(s)* PXC3.Ex-x, DXR2.Ex-x, DXR2.Mx-x, DXR2.T12P-102B, DXR2.T18-101B, DXP2.E18-110BR, DXP2.M18-110BR</b>
Firmware version
<b>01.22.273.16</b>
Vendor
<b>Siemens</b>
<b>Theilerstrasse 1a</b>
<b>6300 Zug, Switzerland</b>

\* where x is according to listing information

This certificate is valid until **31-Mar-2031**.

**12-Mar-2026**

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann'.

Dipl.-Ing. G. Weinmann  
Head of Certification Body