


BACnet CONFORMANCE CERTIFICATE



No. BTL-31531

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.20. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 26.0 and the BTL Testing Policies, see Test Report number TC51521 of Protocol Test Lab.

Product name (B-BC,B-BBMD,B-RTR,B-SCHUB)
Desigo PXC7, PXC5 and PXC4 Automation Station Model(s) PXC5.E003, PXC5.E24, PXC5.E24-N, PXC4.E16, PXC4.E16S, PXC4.E16-2, PXC4.E16S-2, PXC4.M16, PXC4.M16S, PXC4.M16-2, PXC4.M16S-2, PXC7.E400L, PXC7.E400L-N, PXC7.E400S, PXC7.E400M
Firmware version
02.23.273.16
Vendor
Siemens Theilerstrasse 1a 6300 Zug, Switzerland

This certificate is valid until **31-Mar-2031**.

09-Apr-2026

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann
Head of Certification Body