

BACnet CONFORMANCE CERTIFICATE



No. BTL-31593

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.15. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 26.0 and the BTL Testing Policies, see Test Report number TC51546 of Protocol Test Lab.

Product name (B-ASC)
Intelligent Valve
Model(s) ASE4U10A/1, EVG4U10A050/1
Firmware version
1.23.11989
Vendor
Siemens
Theilerstrasse 1a
6300 Zug, Switzerland

This certificate is valid until **31-Mar-2032**.

26-Jun-2026

Date of Initial Certification

Dipl.-Ing. G. Weinmann
Head of Certification Body