

BACnet CONFORMANCE CERTIFICATE



No. BTL-31605

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.15. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 26.1 and the BTL Testing Policies, see Test Report number TC51560 of Protocol Test Lab.

Product name (B-ASC)
BACnet Terminal Box Controller (BTEC)
Model(s) BACNET ATEC I/O 2301, FULL FEATURE (GDE) (550-445); BACNET ATEC I/O 0001, COOLING ONLY (GDE) (550-440); BACNET ATEC I/O 0001, COOLING ONLY (GLB) (550-441); BACNET ATEC I/O 2301, FULL FEATURE (GLB) (550-446); MCQ-550-440 BACnet ATEC MCQ-550-440; MCQ-550-445 BACnet ATEC MCQ-550-445
Firmware version
BZ44 Rev 2.9
Vendor
Siemens
Theilerstrasse 1a
6300 Zug, Switzerland

This certificate is valid until **31-Mar-2032**.

10-Jul-2026
Date of Initial Certification


Dipl.-Ing. G. Weinmann
Head of Certification Body