

# BACnet CONFORMANCE CERTIFICATE



## No. BTL-30573

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.15. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 15.0 and the BTL Testing Policies, see Test Report number TC50832 of SoftDEL.

Product name (B-AAC)
<b>Symbio™</b>
<b>Model(s) 700</b>
Firmware version
<b>4.4.44_SCNbuild-TracerSC-DEVELOPMENT</b>
Vendor
<b>Trane</b>
<b>800E Beaty Street</b>
<b>Davidson, NC 28031, USA</b>

This certificate is valid until **31-Mar-2023**.

**21-Apr-2020**  
Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann', written over a horizontal line.

Dipl.-Ing. G. Weinmann  
Head of Certification Body