

BACnet Protocol Implementation Conformance Statement

BACNET PROTOCOL IMPLEMENTATION CONFORMANCE STATEMENT

Date: xx/xx/xx

Vendor Name: Trend Control Systems Ltd.

Product Name: IQ3

Product Model Number: IQ3xcite/000/BAC..., IQ3xact/012/BAC., IQ3xcite/016/BAC..., IQ3xcite/096/BAC..., IQ3xcite/128/BAC..., IQ3xcite/... + IQ3xcite/BAC/UP, IQ3xact /... + IQ3xact/BAC/UP

Applications Software Version: N/A

Firmware Revision: 2.1

BACnet Protocol Revision: 4

Product Description:

The IQ3 is a configurable plant controller using BACnet over IP to interface with 3rd party BACnet systems.

BACnet Standardized Device Profile (Annex L):

- BACnet Operator Workstation (B-OWS)
- BACnet Building Controller (B-BC)
- BACnet Advanced Application Controller (B-AAC)
- BACnet Application Specific Controller (B-ASC)
- BACnet Smart Sensor (B-SS)
- BACnet Smart Actuator (B-SA)

List all BACnet Interoperability Building Blocks Supported (Annex K):

ID	BIBB	Title
1.1	DS-RP-A	Data Sharing-ReadProperty-A
1.2	DS-RP-B	Data Sharing-ReadProperty-B
1.4	DS-RPM-B	Data Sharing ReadPropertyMultiple-B
1.7	DS-WP-A	Data Sharing-WriteProperty-A
1.8	DS-WP-B	Data Sharing-WriteProperty-B
1.10	DS-WPM-B	Data Sharing-WritePropertyMultiple-B
1.12	DS-COV-B	Data Sharing-ChangeOfValue-B
2.2	AE-N-I-B	Alarm and Event-Notification Internal-B
2.11	AE-INFO-B	Alarm and Event-Information-B
4.2	T-VMT-I-B	Trending-Viewing and Modifying Trends Internal- B
4.5	T-ATR-B	Trending Automated Trend Retrieval-B
5.1	DM-DDB-A	Device Management-Dynamic Device Binding-A
5.2	DM-DDB-B	Device Management-Dynamic Device Binding-B
5.4	DM-DOB-B	Device Management-Dynamic Object Binding-B
5.6	DM-DCC-B	Device Management-DeviceCommunicationControl-B
5.12	DM-TS-B	Device Management-TimeSynchronisation-B
5.14	DM-UTC-B	Device Management-UTCTimeSynchronisation-B
Addendum L		
3.4	SCH-R-B	Scheduling Readable B

Segmentation Capability:

- Segmented requests supported Window Size 1
- Segmented responses supported Window Size 1

Standard Object Types Supported:

An object type is supported if it may be present in the device. For each standard Object Type supported provide the following data:

- 1) Whether objects of this type are dynamically creatable using the CreateObject service
- 2) Whether objects of this type are dynamically deletable using the DeleteObject service
- 3) List of the optional properties supported
- 4) List of all properties that are writable where not otherwise required by this standard
- 5) List of proprietary properties and for each its property identifier, datatype, and meaning
- 6) List of any property range restrictions

Analog Input Object Type

1. Creatable: No
2. Deletable: No
3. Optional Properties Supported:
 - BP_DEVICE_TYPE
 - BP_RELIABILITY
 - BP_EVENT_ENABLE
 - BP_HIGH_LIMIT
 - BP_LIMIT_ENABLE
 - BP_LOW_LIMIT
 - BP_NOTIFICATION_CLASS
 - BP_TIME_DELAY
 - BP_ACKED_TRANSITIONS
 - BP_NOTIFY_TYPE
 - BP_DEADBAND
 - BP_EVENT_TIMESTAMPS
 - BP_COV_INCREMENT
4. Writeable Properties:
 - BP_EVENT_ENABLE
 - BP_HIGH_LIMIT
 - BP_LIMIT_ENABLE
 - BP_LOW_LIMIT
 - BP_NOTIFICATION_CLASS
 - BP_TIME_DELAY
 - BP_COV_INCREMENT
5. Proprietary Properties: None
6. Property Range Restrictions:

BP_PRESENT_VALUE	1.175494351e-38F to 3.402823466e+38F, resolution: to 7 digits
BP_UNITS	0 to 255 bytes
BP_HIGH_LIMIT	-1e20 to 1e20, resolution: 7 digits
BP_LOW_LIMIT	-1e20 to 1e20, resolution: 7 digits
BP_DEADBAND	-1e20 to 1e20, resolution: 7 digits
BP_TIME_DELAY	0 to 172800, resolution: 1

Analogue Output Object Type

1. Creatable: No
2. Deletable: No
3. Optional Properties Supported:
 - BP_DEVICE_TYPE
 - BP_RELIABILITY
 - BP_COV_INCREMENT
4. Writeable Properties:
 - BP_PRESENT_VALUE
 - BP_COV_INCREMENT
5. Proprietary Properties: None
6. Property Range Restrictions:

BP_PRESENT_VALUE	1.175494351e-38F to 3.402823466e+38F, resolution: to 7 digits
BP_UNITS	0 to 255 bytes
BP_RELINQUISH_DEFAULT	-1e20 to 1e20, resolution: 7 digits

Analogue Value Object Type

1. Creatable: No
2. Deletable: No
3. Optional Properties Supported:
 - BP_RELIABILITY
 - BP_COV_INCREMENT
4. Writeable Properties:
 - BP_PRESENT_VALUE
 - BP_UNITS
 - BP_COV_INCREMENT
5. Proprietary Properties: None
6. Property Range Restrictions:
 - BP_PRESENT_VALUE 1.175494351e-38F to 3.402823466e+38F, resolution: to 7 digits
 - BP_UNITS 0 to 255 bytes

Binary Input Object Type

1. Creatable: No
2. Deletable: No
3. Optional Properties Supported:
 - BP_DEVICE_TYPE
 - BP_ALARM_VALUE
 - BP_ELAPSED_ACTIVE_TIME
 - BP_EVENT_ENABLE
 - BP_NOTIFICATION_CLASS
 - BP_NOTIFY_TYPE
 - BP_RELIABILITY
 - BP_TIME_DELAY
 - BP_ACKED_TRANSITIONS
 - BP_EVENT_TIME_STAMPS
 - BP_TIME_OF_ACTIVE_TIME_RESET
4. Writeable Properties:
 - BP_ALARM_VALUE
 - BP_ELAPSED_ACTIVE_TIME
 - BP_EVENT_ENABLE
 - BP_NOTIFICATION_CLASS
 - BP_TIME_DELAY
5. Proprietary Properties:
6. Property Range Restrictions: None
 - BP_ELAPSED_ACTIVE_TIME 0 to 235926008, resolution: 1
 - BP_TIME_DELAY 0 to 172800, resolution: 1

Binary Output Object Type

1. Creatable: No
2. Deletable: No
3. Optional Properties Supported:
 - BP_DEVICE_TYPE
 - BP_CHANGE_OF_STATE_COUNT
 - BP_ELAPSED_ACTIVE_TIME
 - BP_RELIABILITY
 - BP_CHANGE_OF_STATE_TIME
 - BP_TIME_OF_STATE_COUNT_RESET
 - BP_TIME_OF_ACTIVE_TIME_RESET
 - BP_TIME_DELAY
 - BP_NOTIFICATION_CLASS
 - BP_FEEDBACK_VALUE
 - BP_EVENT_ENABLE
 - BP_ACKED_TRANSITIONS
 - BP_NOTIFY_TYPE
 - BP_EVENT_TIME_STAMPS
4. Writeable Properties:
 - BP_PRESENT_VALUE
 - BP_CHANGE_OF_STATE_COUNT
 - BP_ELAPSED_ACTIVE_TIME
 - BP_TIME_DELAY
 - BP_NOTIFICATION_CLASS
 - BP_EVENT_ENABLE
5. Proprietary Properties: None
6. Property Range Restrictions:
 - BP_CHANGE_OF_STATE_COUNT 0 to 1,000,000,000
 - BP_ELAPSED_ACTIVE_TIME 0 to 235926008, resolution 1
 - BP_TIME_DELAY 0 to 172800, resolution: 1

Binary Value Object Type

1. Creatable: No
2. Deletable: No
3. Optional Properties Supported:
 - BP_RELIABILITY
4. Writeable Properties:
 - BP_PRESENT_VALUE
5. Proprietary Properties: None
6. Property Range Restrictions: None

Device Object Type

1. Creatable: No
2. Deletable: No
3. Optional Properties Supported:
 - BP_LOCATION
 - BP_MAX_SEGMENTS_ACCEPTED
 - BP_LOCAL_DATE
 - BP_LOCAL_TIME
 - BP_UTC_OFFSET
 - BP_DAYLIGHT_SAVINGS_STATUS
 - BP_APDU_SEGMENT_TIMEOUT
 - BP_ACTIVE_COV_SUBSCRIPTIONS
4. Writeable Properties:
 - BP_LOCAL_DATE
 - BP_LOCAL_TIME
 - BP_UTC_OFFSET
5. Proprietary Properties: None
6. Property Range Restrictions:
 - BP_UTC_OFFSET -780 to +780, resolution: 1

Notification Class Object Type

1. Creatable: No
2. Deletable: No
3. Optional Properties Supported: None
4. Writeable Properties:
 - BP_RECIPIENT_LIST
 - BP_NOTIFICATION_THRESHOLD
5. Proprietary Properties: None
6. Property Range Restrictions: None

Schedule Object Type

1. Creatable: No
2. Deletable: No
3. Optional Properties Supported:
 - BP_WEEKLY_SCHEDULE
 - BP_EXCEPTION_SCHEDULE
4. Writeable Properties: None
5. Proprietary Properties: None
6. Property Range Restrictions: None

Trend Log Object

1. Creatable: No
2. Deletable: No
3. Optional Properties Supported:
 - BP_NOTIFICATION_THRESHOLD
 - BP_RECORDS_SINCE_NOTIFICATION
 - BP_LAST_NOTIFY_RECORD
 - BP_NOTIFICATION_CLASS
 - BP_EVENT_ENABLE
 - BP_ACKED_TRANSITIONS
 - BP_NOTIFY_TYPE
 - BP_EVENT_TIME_STAMPS
4. Writeable Properties:
 - BP_LOG_INTERVAL
 - BP_RECORD_COUNT
 - BP_LOG_ENABLE
5. Proprietary Properties: None
6. Property Range Restrictions:
 - BP_LOG_INTERVAL 0 to 235926000, resolution 1
 - BP_RECORD_COUNT 0 to 235926000, resolution 1

Data Link Layer Options:

- BACnet IP, (Annex J)
- BACnet IP, (Annex J), Foreign Device
- ISO 8802-3, Ethernet (Clause 7)
- ANSI/ATA 878.1, 2.5 Mb. ARCNET (Clause 8)
- ANSI/ATA 878.1, RS-485 ARCNET (Clause 8), baud rate(s):
- MS/TP master (Clause 9), baud rate(s):
- MS/TP slave (Clause 9), baud rate(s):
- Point-To-Point, EIA 232 (Clause 10), baud rate(s):
- Point-To-Point, modem, (Clause 10), baud rate(s):
- LonTalk, (Clause 11), medium:
- Other:

Device Address Binding:

Is static device binding supported? (This is currently necessary for two-way communication with MS/TP slaves and certain other devices.) Yes No

Networking Options:

- Router, Clause 6 - List all routing configurations, e.g., ARCNET-Ethernet, Ethernet-MS/TP, etc.
 - Annex H, BACnet Tunneling Router over IP
 - BACnet/IP Broadcast Management Device (BBMD)
- Does the BBMD support registrations by Foreign Devices? Yes No

Character Sets Supported:

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

- ANSI X3.4
- IBM™/Microsoft™ DBCS
- ISO 8859-1
- ISO 10646 (UCS-2)
- ISO 10646 (UCS-4)
- JIS C 6226

If this product is a communication gateway, describe the types of non-BACnet equipment/networks(s) that the gateway supports:

N/A

Please send any comments about this or any other Trend technical publication to techpubs@trendcontrols.com

© 2009 Honeywell Technologies Sàrl, ECC Division. All rights reserved. Manufactured for and on behalf of the Environmental and Combustion Controls Division of Honeywell Technologies Sàrl, Z.A. La Pièce, 16, 1180 Rolle, Switzerland by its Authorized Representative, Trend Control Systems Limited.

Trend Control Systems Limited reserves the right to revise this publication from time to time and make changes to the content hereof without obligation to notify any person of such revisions or changes.

Trend Control Systems Limited

P.O. Box 34, Horsham, West Sussex, RH12 2YF, UK. Tel:+44 (0)1403 211888 Fax:+44 (0)1403 241608 www.trend-controls.com

Trend Control Systems USA

6670 185th Avenue NE, Redmond, Washington 98052, USA. Tel: (425)897-3900, Fax: (425)869-8445 www.trend-controls.com